



RESISTANCE READINGS TEST RESULTS

Please make a note of your resistance readings in the table below. This will support your guarantee. Readings need to be taken with an ordinary Multimeter.

Please also make a note of the resistance readings on your registration card.

Readings 1., 2. and 3. are performed on the mat "cold tail" connecting lead and reading 4. on the two wires of the floor temperature sensor.

<u>Mat Rating:</u>	<u>W</u>	<u>Initial Test</u>	<u>Mat Laid</u>	<u>Completion</u>
1. Live & Neutral		Ω	Ω	Ω
2. Live & Earth*		Ω	Ω	Ω
3. Neutral & Earth*		Ω	Ω	Ω
4. Floor Temperature Sensor		Ω	Ω	Ω

* This should always read open circuit. If not, STOP immediately and call the Philex Support Line: **08457 573 479** (local rate number in the UK)

Email: heating@philex.com

or visit: Technical Support: <http://technical.philex.com>